

PH: 051-9077540  
051- 9215591

**PAKISTAN TELEVISION CORPORATION LIMITED**  
**PTV NEWS CENTRE**  
**F-5/1 Agha Khan Road, Islamabad**

Ref: PTV-News/ES-06/2016/1745  
Date 29.03.2016


**PURCHASE ENQUIRY**

PTV invites applications for prequalification/quotation from Firms/Suppliers for the **Supply, Installation, Testing and Commissioning** of Vehicle Mount Diesel Generator for DSNG Van of PTV Islamabad Centre as per Pre-qualification documents given below.

<b>SCOPE OF WORK</b>																																																	
The purchaser PTV intends to prequalify suppliers for task described One No. <b>VEHICLE MOUNT DIESEL GENERATOR FOR DSNG VAN</b> is required																																																	
Sr. No.	Description and Specification of Goods	Unit	Quantity Required																																														
1.	<b>Specification of the said Generator (Fisher Panda) or equivalent</b>  <b>TECHNICAL SPECIFICATIONS</b> <table border="1"><tr><td>Power Rating</td><td>10.20KW</td></tr><tr><td>Nominal Speed (RPM)</td><td>3000</td></tr><tr><td>Voltage Regulation</td><td>VCS(Perfect Sine Wave)</td></tr><tr><td>Power Rating Factor</td><td>0.85</td></tr><tr><td>Excitation by</td><td>MKP Capacitors</td></tr><tr><td>Isolation Class of Winding</td><td>H</td></tr><tr><td>Attenuator Type</td><td>HP1</td></tr><tr><td>Number of Phases</td><td>Single</td></tr><tr><td>Frequency</td><td>50Hz</td></tr><tr><td>Output Voltage</td><td>220-230 Volts</td></tr><tr><td>Rated Current</td><td>44.3 Amp(Approx)</td></tr><tr><td>Alternator for Charging</td><td>12V/10A</td></tr><tr><td>Cooling Type</td><td>Water Cooled</td></tr><tr><td>Sound insulation cover</td><td>Glass Fiber Reinforced Polyester</td></tr></table> <b>GENERAL SPECIFICATION</b> <table border="1"><tr><td>Brushless</td><td></td></tr><tr><td>No Signal Noise</td><td></td></tr><tr><td>No rotating coils or diodes</td><td></td></tr><tr><td>Precise Control</td><td></td></tr><tr><td>High Protection Rating</td><td></td></tr><tr><td>Short Circuit Stability</td><td></td></tr><tr><td>Overload Protection</td><td></td></tr><tr><td>Approx Space for Generator</td><td>L-38", W-24", H-25"</td></tr><tr><td>Approx Space for Radiator (Roof Mounted) Along with DC Operated Cooling Fans</td><td>L-43", W20", H-12"</td></tr></table>	Power Rating	10.20KW	Nominal Speed (RPM)	3000	Voltage Regulation	VCS(Perfect Sine Wave)	Power Rating Factor	0.85	Excitation by	MKP Capacitors	Isolation Class of Winding	H	Attenuator Type	HP1	Number of Phases	Single	Frequency	50Hz	Output Voltage	220-230 Volts	Rated Current	44.3 Amp(Approx)	Alternator for Charging	12V/10A	Cooling Type	Water Cooled	Sound insulation cover	Glass Fiber Reinforced Polyester	Brushless		No Signal Noise		No rotating coils or diodes		Precise Control		High Protection Rating		Short Circuit Stability		Overload Protection		Approx Space for Generator	L-38", W-24", H-25"	Approx Space for Radiator (Roof Mounted) Along with DC Operated Cooling Fans	L-43", W20", H-12"	No	01
Power Rating	10.20KW																																																
Nominal Speed (RPM)	3000																																																
Voltage Regulation	VCS(Perfect Sine Wave)																																																
Power Rating Factor	0.85																																																
Excitation by	MKP Capacitors																																																
Isolation Class of Winding	H																																																
Attenuator Type	HP1																																																
Number of Phases	Single																																																
Frequency	50Hz																																																
Output Voltage	220-230 Volts																																																
Rated Current	44.3 Amp(Approx)																																																
Alternator for Charging	12V/10A																																																
Cooling Type	Water Cooled																																																
Sound insulation cover	Glass Fiber Reinforced Polyester																																																
Brushless																																																	
No Signal Noise																																																	
No rotating coils or diodes																																																	
Precise Control																																																	
High Protection Rating																																																	
Short Circuit Stability																																																	
Overload Protection																																																	
Approx Space for Generator	L-38", W-24", H-25"																																																
Approx Space for Radiator (Roof Mounted) Along with DC Operated Cooling Fans	L-43", W20", H-12"																																																

**Terms and Conditions:**

1. Only the firms / suppliers already registered with sales tax / Income Tax Department can participate. The Firms / Suppliers will quote prices including all taxes.
2. PTV reserves the right to either accept or reject any or all the price quotations prior to the acceptance of a bid.
3. The tender must accompany earnest money 2% of the total the bid amount in the form of Call Deposit/Bank Draft (refundable) drawn in favour of PTV Hqrs Islamabad.
4. The tenderer must participate in all the items (no partial bidding is allowed.)
5. The delivery of the material at PTV News Centre will be at supplier's risk / cost.
6. Tender should contain complete specifications of the equipment.

  
(Executive Engineering Manager)

For Pakistan Television Corporation Limited

**INSTRUCTIONS**

1. Please also indicate your earliest delivery date. Your quotation must reach the office of the General Manager, Chairman Tender Committee by 12 noon on or before **30.04.16** Please note that the corporation reserves the right to reject all the quotations with out showing any cause whatsoever.
2. Please also indicate your earlier delivery date.
3. Quotation must be addressed to GENERAL MANAGER TV CENTRE, Islamabad. Tender will be opened on **30.04.16** Purchase Enquiry No. & Date of opening must be written on the sealed envelope.
4. Your quotations must reach the office 12 noon on or before **30.04.16** Please note that Corporation reserves the right to reject all the quotations without showing any cause whatsoever.
5. The quotations must be submitted on a sealed envelope and dispatched under Registered Post.
6. Delivery of the Material will be at your risk and cost.